



# TEST REPORT

DATE: 03-24-2017

Page 1 of 1

TEST NUMBER: 0236132

<b>CLIENT</b>	SuZhou Tuntex Fiber & Carpet Company
---------------	--------------------------------------

<b>TEST METHOD CONDUCTED</b>	ASTM D6540 Standard Test Method for Accelerated Soiling of Pile Yarn Floor Covering
------------------------------	---



DESCRIPTION OF TEST SAMPLE	
<b>IDENTIFICATION</b>	Nexlon Premium solution Dyed Nylon with Stain Shield & Soil Guard
<b>CONSTRUCTION</b>	Multi-Level Loop Pile
<b>BACKING</b>	Thermoplastic

### GENERAL PRINCIPLE

This test method is designed to provide an accelerated means to simulate floor service soiling. Test specimens are tumbled with prepared soil in a sealed container for a predetermined time. After soiling, the test sample is vacuumed. By comparing the cleaned sample to an original "control" sample, any change which may have occurred is assessed and rated by means of the AATCC Gray Scale for Color Change.

### TEST RESULTS

IDENTIFICATION	SOIL RATING (After Vacuum)
Nexlon Premium solution Dyed Nylon with Stain Shield & Soil Guard	2.5

AATCC RATING KEY	
5	Negligible or no change
4	Slight change
3	Noticeable change
2	Considerable change
1	Severe change

APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.