

TEST REPORT

DATE:10-07-2024 Page 1 of 1 **TEST NUMBER:**0311813

TEST METHOD CONDUCTED	ASTM D1335 Standard Test Method for Tuft Bind of Pile Yarn Floor
	Coverings

DESCRIPTION OF TEST SAMPLE		
IDENTIFICATION	Nexlon Carpet Tile	
CONSTRUCTION	Multi-Level Loop Pile	
BACKING	Duraback	

GENERAL PRINCIPLE

This test method is designed to measure the force required to pull a tuft completely out of a pile floor covering. It is applicable to both cut and looped pile construction. In the event the material contains both cut and loop, only the loop pile is tested.

TEST RESULTS

15.5	10.9	11.8	9.7	9.9
14.6	13.1	9.2	12.0	11.0
11.7	10.7	11.2	12.8	9.2

	-
AVERAGE TUFT BIND	11.6 Lbs.

714 Glenwood Place

This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Lab Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any agency of the United States Government for the product tested. This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product ested. This report duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory, LLC, shall not be used under any circumstance in advertising to the general public.

